

Sec. 32-140. - Stormwater collection system.

- (a) Whether it is provided by means of open ditches, closed storm drains, or curbs and gutters, the subdivision shall have an adequate stormwater collection system. Storm sewers and drainage structures shall be designed and installed as required in accordance with good engineering practice. The minimum pipe diameter of storm drains shall be 15 inches. In no case shall stormwater empty into the sanitary sewer system.
- (b) Where a storm sewer system is reasonably accessible to the subdivision, the subdivider shall connect with such network and install all drainage structures necessary to convey the water to the storm drainage system. Where a storm drainage system is not accessible, the subdivider shall install all drainage structures necessary to convey the water to a location acceptable to the town.
- (c) All open drainage ditches shall either be paved with a material acceptable to the town or be designed and stabilized in a manner acceptable to the town engineer.

(Ord. of 6-25-2007, § 12.8.5)